

Customer No.: 123456 Inspect. rec. No.: 22 Order No.: 25846

ELECTRICAL EQUIPMENT TEST REPORT

Full detailed PRO



Room Elma Instruments				Building						
Appliance/Project KLASSE 1				Test Date 23. Apr 2000			Status Pass			
				Retest Date 23. Oct 2000						
Appliance name/Device				Comment						
				Test Site Elma Instruments						
Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result 1	Status
Visual Test										Pass
Earth Continuity	200mA	5s						0.30 Ω	0.00 Ω	Pass
Insulation	500V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 525 V	Pass
Subleakage	30.0V	2s	230V					3.50 mA	0.01 mA	Pass
Appliance/Project KLASSE 2				Test Date 23. Apr 2000			Status Pass			
				Retest Date 23. Oct 2000						
Appliance name/Device				Comment						
				Test Site Elma Instruments						
Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result 1	Status
Visual Test										Pass
Insulation-P	500V	2s						2 MΩ	R = >200 MΩ	Pass
									Um = 525 V	Pass
Subleakage-P	30.0V	2s	230V					0.50 mA	0.00 mA	Pass

Signature: _____ Customer: _____ Operator: _____