

# MN93, MN93A PAC93, C193 MiniFlex<sup>®</sup> MA193 and MA196 AmpFlex<sup>®</sup> A193, and A196A



**Current sensors**

***English***

# ENGLISH

Thank you for purchasing a **MN93, MN93A, C193 or PAC93 AC current clamp or a MiniFlex® MA193 or MA196, AmpFlex® A193 or A196A flexible current sensor**. This current sensor should only be used only with C.A 82XX, C.A 83XX, C.A 84XX and PEL 1XX analysers.

For best service from your current sensor:

- **read** these operating instructions carefully,
- **comply** with the precautions for use.



WARNING, risk of DANGER! The operator must refer to these instructions whenever this danger symbol appears.



Current sensor protected by double insulation.



Application or withdrawal authorized on bare conductors carrying dangerous voltages. Type A current sensor as per IEC 61010-2-032.



Must not be applied to or removed from bare conductors at dangerous voltages. Type B current sensor as per IEC 61010-2-032.



The arrow indicates the phase of the current.



Battery.



The CE marking guarantees conformity with European directives, in particular LVD and EMC.



The rubbish bin with a line through it indicates that, in the European Union, the product must undergo selective disposal in compliance with Directive WEEE 2002/96/EC. This equipment must not be treated as household waste.

## Definition of measurement categories:

- Measurement category IV corresponds to measurements taken at the source of low-voltage installations.  
Example: power feeders, counters and protection devices.
- Measurement category III corresponds to measurements on building installations.  
Example: distribution panel, circuit-breakers, machines or fixed industrial devices.
- Measurement category II corresponds to measurements taken on circuits directly connected to low-voltage installations.  
Example: power supply to electro-domestic devices and portable tools.

# PRECAUTIONS FOR USE

The protection assured by the current sensor can be compromised if it is used in a way that is not recommended by the manufacturer.


- Comply with the rated maximum voltage and current and the measurement category. Do not use your current sensor on networks where the voltage or category exceeds those stipulated.
- Comply with the conditions of use, that is to say temperature, humidity, altitude, degree of pollution and location of use.
- Do not use the current sensor if its housing is open, deteriorated, or incorrectly reassembled. Before each use, check the integrity of the insulation of the core or of the arms of the clamps, of the housing, and of the leads.
- Do not subject the current sensor to sprayed or falling water or other liquids.
- Keep the gap of the clamp absolutely clean.
- Use suitable personal protective equipment when parts at hazardous voltages may be accessible in the installation where the measurement is made.
- Any repairs must be carried out by accredited skilled personnel.

## CONTENTS


<b>1. PRESENTATION</b> .....	<b>5</b>
1.1. Clamps MN93 and MN93A.....	5
1.2. Clamp C193 .....	6
1.3. Clamp PAC93 .....	7
1.4. MiniFlex® MA193 .....	8
1.5. MiniFlex® MA196 .....	9
1.6. AmpFlex® A193.....	10
1.7. AmpFlex® A196A .....	11
1.8. Delivery condition .....	12
<b>2. USE</b> .....	<b>13</b>
<b>3. CHARACTERISTICS</b> .....	<b>16</b>
3.1. Environmental conditions .....	16
3.2. Construction specifications .....	16
3.3. Conformity to international standards.....	17
<b>4. MAINTENANCE</b> .....	<b>18</b>
4.1. Cleaning .....	18
4.2. Replacing the battery of the PAC93 .....	18
<b>5. WARRANTY</b> .....	<b>19</b>

# 1. PRESENTATION


## 1.1. CLAMPS MN93 AND MN93A



## 1.2. CLAMP C193




### 1.3. CLAMP PAC93



## 1.4. MINIFLEX® MA193


Core of the flexible sensor.






## 1.5. MINIFLEX® MA196

The connector on this sensor can be used to form a seal with the terminal to which it is connected, if the instrument has a threaded receptacle. Simply screw the ring on the connector onto the receptacle.




## 1.6. AMPFLEX® A193




## 1.7. AMPFLEX® A196A

The connector on this sensor can be used to form a seal with the terminal to which it is connected, if the instrument has a threaded receptacle. Simply screw the ring on the connector onto the receptacle.



Threaded ring.



## 1.8. DELIVERY CONDITION

### **Clamp MN93**

Supplied in a cardboard box with:

- a user manual in 5 languages,
- a verification certificate.

### **Clamp MN93A**

Supplied in a cardboard box with:

- a user manual in 5 languages,
- a verification certificate.

### **Clamp PAC93**

Supplied in a cardboard box with:

- a user manual in 5 languages,
- a verification certificate.

### **Clamp C193**

Supplied in a cardboard box with:

- a user manual in 5 languages,
- a verification certificate.

### **MiniFlex® MA193 250mm sensor**

Supplied in a cardboard box with:

- a user manual in 5 languages,
- a verification certificate.
- 

### **MiniFlex® MA193 350mm sensor**

Supplied in a cardboard box with:

- a user manual in 5 languages,
- a verification certificate.

### **MiniFlex® MA196 350mm sensor**

Supplied in a cardboard box with:

- a user manual in 5 languages,
- a verification certificate.

### **AmpFlex® A193 450mm sensor**

Supplied in a cardboard box with:

- a user manual in 5 languages,
- a verification certificate.

### **AmpFlex® A193 800mm sensor**

Supplied in a cardboard box with:

- a user manual in 5 languages,
- a verification certificate.

### **AmpFlex® A196A 610mm sensor**

Supplied in a cardboard box with:

- a user manual in 5 languages,
- a verification certificate.

## 2. USE

Current clamps, MiniFlex® and AmpFlex® flexible current sensors are used to measure the current flowing in a cable without opening the circuit. They also insulate the user from dangerous voltages in the circuit.

The choice of current sensor to be used depends on the current to be measured and the diameter of the cables.

	MN93	MN93A 5 A	MN93A 100 A
Measurement range *	0.05 - 240 A	0.005 - 6 A	0.1 - 120 A
Clamping diameter	20 mm	20 mm	20 mm

	C193	PAC93
Measurement range *	1 - 1.200 A	1 - 1.200 A
Clamping diameter	52 mm	39 mm

	MiniFlex® MA193 250 mm	MiniFlex® MA193 350 mm	MiniFlex® MA196 350 mm
Measurement range *	100 mA - 10 000 A	100 mA - 10 000 A	100 mA - 10 000 A
Clamping diameter	70 mm	100 mm	100 mm


	AmpFlex® A193 450 mm	AmpFlex® A196A 610 mm	AmpFlex® A193 800 mm
Measurement range *	100 mA - 10 000 A	100 mA - 10 000 A	100 mA - 10 000 A
Clamping diameter	120 mm	170 mm	235 mm

\* : The measurement ranges are those of the sensors. In some cases, they may differ from the ranges that can be measured by the analyser with which they are associated.

- For three-phase measurements, start by marking the accessories using the coloured rings supplied with the device: a different colour for each current terminal.
- Connect the current sensors to the current terminals of the device.

### For the PAC93:


- Set the switch to "1 mV/A"; the "ON" indicator lights.
- Once the PAC93 is connected to the device, adjust the zero by turning the potentiometer with no conductor in the jaws of the clamp.



- At the end of the measurement, remember to switch off the PAC93.

### For the clamps:


- Press the trigger on the clamp to open the jaws.
- Then clamp the cable that is to be measured. Where possible, the cable should be centred in the jaws of the clamp.



- Release the trigger.

### For the MiniFlex® models:

- Press on the yellow opening device to open the flexible coil.
- Open it and place it around the conductor carrying the current to be measured (only one conductor in the sensor). Where possible, the cable should be centred in the sensor.




or

- Close the coil. You must hear the click.

### For the AmpFlex® models:

- Press simultaneously on both sides of the opening device.
- Then clamp the cable that is to be measured. Where possible, the cable should be centred in the sensor.



- Close the sensor by forcing the moving part into the connector until you hear a click.

**For details of the measurement configuration and technical characteristics, refer to the user manual of the analyser with which you are using the current sensor.**

# 3. CHARACTERISTICS

## 3.1. ENVIRONMENTAL CONDITIONS

Indoor use.

Operating range	-10 °C to +55 °C and 10 % to 85% RH
Storage range	-40 °C to +70 °C and 10 % to 90% RH
Degree of pollution	2
Altitude	< 2000 m

## 3.2. CONSTRUCTION SPECIFICATIONS

### MN93 and MN93A

■ Dimensions (L x W x H)	135 x 51 x 30 mm
■ Cord	3.50 metres long
■ Weight	approx. 290 g

### C193

■ Dimensions (L x W x H)	216 x 111 x 45 mm
■ Cord	3.50 metres long
■ Weight	approx. 690 g

### PAC93

■ Dimensions (L x W x H)	236.5 x 97 x 44 mm
■ Cord	3.50 metres long
■ Weight	approx. 540 g
■ Battery life	120 hours with an alkaline battery

### MiniFlex® MA193 250 mm

■ Dimensions (L x W x H)	approx. 130 x 74 x 12 mm
■ Cord	3 metres long
■ Weight	approx. 70 g

### MiniFlex® MA193 and MA196 350 mm

■ Dimensions (L x W x H)	approx. 170 x 103 x 18 mm
■ Cord	3 metres long
■ Weight	approx. 110 g

### AmpFlex® A193 450 mm

■ Dimensions (L x W x H)	approx. 170 x 158 x 25 mm
■ Cord	3 metres long
■ Weight	approx. 220 g

### AmpFlex® A193 800 mm

■ Dimensions (L x W x H)	approx. 280 x 265 x 25 mm
■ Cord	3 metres long
■ Weight	approx. 270 g

### AmpFlex® A196A 610 mm

■ Dimensions (L x W x H)	approx. 215 x 200 x 25 mm
■ Cord	3 metres long
■ Weight	approx. 250 g



## Protection index

- IP 40 for the clamps and IP 30 jaws open, according to IEC 60 529
- IP 50 for the MiniFlex® MA193 according to IEC 60 529
- IP 67 for the MiniFlex® MA196 according to IEC 60 529 when the ring is screwed on
- IP 65 for the AmpFlex® A193 according to IEC 60 529
- IP 67 for the AmpFlex® A196A according to IEC 60 529 when the ring is screwed on
  
- IK 04 according to IEC 50102

Drop test: according to IEC 61010-1






## 3.3. CONFORMITY TO INTERNATIONAL STANDARDS

Electrical safety according to IEC 61010-2-032.


Maximum applicable voltage:

- MN93 and MN93A: 600 V Cat III or 300 V Cat IV
- C193: 1000 V Cat III or 600 V Cat IV
- PAC93: 600 V Cat III or 300 V Cat IV
- MiniFlex® : 1000 V Cat III ou 600 V Cat IV
- AmpFlex®: 1000 V Cat III or 600 V Cat IV

Type of current sensor as per IEC 61010-2-032:

- MN93 et MN93A : type A 
- C193 : type A 
- PAC93 : type A 
- MiniFlex® : type B 
- AmpFlex® : type B 

## 4. MAINTENANCE

 Except for the batteries, the instrument contains no parts that can be replaced by personnel who have not been specially trained and accredited. Any unauthorized repair or replacement of a part by an “equivalent” may gravely impair safety.

### 4.1. CLEANING

Disconnect the current sensor completely.


Use a soft cloth, dampened with soapy water. Rinse with a damp cloth and dry rapidly with a dry cloth or forced air. Do not use alcohol, solvents, or hydrocarbons.

Keep the air gaps of the clamps perfectly clean.

See to it that no foreign body interferes with the operation of the snap lock device of the sensor.


### 4.2. REPLACING THE BATTERY OF THE PAC93

- Disconnect the PAC93 completely and turn the rotary switch to OFF.
- Turn the PAC93 over.
- Use a screwdriver to unscrew the screws and remove the battery compartment cover.



- Withdraw the battery from its compartment without pulling on the wires.

- Disconnect the old battery without pulling on the wires and connect the new one in its place, observing the polarity.

 Spent batteries must not be treated as ordinary household waste. Take them to the appropriate recycling collection point.

- Put the battery into its compartment.
- Put the cover back in place and screw the screws back in.

## 5. WARRANTY

---

Except as otherwise stated, our warranty is valid for **twelve months** starting from the date on which the equipment was sold. Extract from our General Conditions of Sale provided on request.

The warranty does not apply in the following cases:

- Inappropriate use of the equipment or use with incompatible equipment;
- Modifications made to the equipment without the explicit permission of the manufacturer's technical staff;
- Work done on the device by a person not approved by the manufacturer;
- Adaptation to a particular application not anticipated in the definition of the equipment or not indicated in the user's manual;
- Damage caused by shocks, falls, or floods.

## FRANCE

### **Chauvin Arnoux Group**

190, rue Championnet

75876 PARIS Cedex 18

Tél : +33 1 44 85 44 85

Fax : +33 1 46 27 73 89

[info@chauvin-arnoux.com](mailto:info@chauvin-arnoux.com)

[www.chauvin-arnoux.com](http://www.chauvin-arnoux.com)

## INTERNATIONAL

### **Chauvin Arnoux Group**

Tél : +33 1 44 85 44 38

Fax : +33 1 46 27 95 69

### **Our international contacts**

[www.chauvin-arnoux.com/contacts](http://www.chauvin-arnoux.com/contacts)

